



CERTIFIKAT

No. 16 49 07

Data media inserts

Holder/Issued to/Manufacturer

Diplomat Safe Ltd, 1583-4 Songjung-dong , Gangseo-gu BUSAN, Korea

Product

Data media inserts. For details, see attached appendix

Product name

See attached appendix

Product information

See attached appendix

Fire resistance class

See attached appendix

Performance specification

NT FIRE 017 and SP's certification rules for fire resisting storage cabinets, SPCR 002.

Marking

Marking on the product shall show the name of the product, its fire resistance class, its serial number, the number of this certificate and SP's -symbol.

Validity

This certificate is valid until not longer than 31st July 2016.

Miscellaneous

The manufacturer's in-house inspection is under surveillance by SP in accordance with section 4 and 5 of SPCR 002. Other terms and conditions are set out in section 6 of SPCR 002.

This is the 8th issue of this certificate, replacing earlier issues. The certificate was originally issued on 2nd July 2006.

Borås, 31st July 2011

SP Technical Research Institute of Sweden Certification


Lennart Månsson
Certification Manager


Lennart Aronsson
Certification Officer

Certificate issued by an Accredited Certification Body

SP Technical Research Institute of Sweden

Postal address	Phone / Fax	Reg. number	E-mail / Internet
SP	+46 10 516 50 00	556464-6874	info@sp.se
Box 857	+46 33 13 55 02		www.sp.se
SE-501 15 Borås			
SWEDEN			

Swedish accredited certification bodies are appointed by SWEDAC , the Swedish Board for Accreditation and Conformity Assessment, under the terms of the Act. This certificate may not be reproduced other than in full, except with the prior written approval by SP.




Product information

The products are sold under different brand names, see table 3

Table 1, models covered by the certificate

Insert model	External dimensions (mm)			Internal dimensions (mm)			Weight (kg)	Fire resistance class, see table 2
	width	height	depth	width	height	depth		
DS 1125	255	310	295	156,5	224	206	9	A
DS 1530	295	400	290	196,5	314	201	13	A
DS 1060	345	470	290	246,5	384	201	15	A
DS 1070	375	505	320	276,5	419	231	18	A
DC 3070	375	190	320	276,5	104	231	10	A
DC 3080	375	190	320	276,5	104	231	10	A
DIS 0708	375	190	320	276,5	104	231	10	A
DIS 6500	490	307,5	430	391,5	221,5	341	21	A
DC 3100	470	425	340	371,5	339	251	22	A
DC 3110	470	425	340	371,5	339	251	22	A
DC 3120	470	425	340	371,5	339	251	22	A
DIF 01	380	265	500	282	165	402	20	A
DIS 1120	470	425	340	371,5	339	251	22	A
DT 2825	505	580	500	401,5	489	406	38	B
DT 2120	505	970	500	401,5	879	406	56	B
DT 2130	505	1195	500	401,5	1104	406	67	B
DT 2200	505	1495	500	401,5	1404	406	83	B
DT 2300(Left)	505	1495	500	401,5	1404	406	83	B
DT 2300(Right)	505	1495	500	401,5	1404	406	83	B

Appendix page 1(2) Sign: 

SP Technical Research Institute of Sweden

Postal address Phone / Fax Reg. number E-mail / Internet
 SP +46 10 516 50 00 556464-6874 info@sp.se
 Box 857 +46 33 13 55 02 www.sp.se
 SE-501 15 Borås
 SWEDEN

Swedish accredited certification bodies are appointed by SWEDAC, the Swedish Board for Accreditation and Conformity Assessment, under the terms of the Act. This certificate may not be reproduced other than in full, except with the prior written approval by SP.

Table 2, Fire resistance class

Note	Fire resistance class	It is a condition that the data media insert is placed inside a document cabinet with the fire resistance class:
A	NT FIRE 017 – 120 Data / NT FIRE 017 – 90 Diskette	NT FIRE 017 – 120 Paper / NT FIRE 017 – 90 Paper
B	NT FIRE 017 – 120 Diskette	NT FIRE 017 – 120 Paper

Table 3, List of related brands and descriptions

Diplomat SAFE LTD	Diplomat SAFE AB	Phoenix SAFE	Yale
DS 1125	-	2001	YDM-420-FG2
DS 1530	-	-	YDM-520-FG2
DS 1060	-	2002	-
DS 1070	-	-	-
DC 3070	-	2501	-
DC 3080	RDL180D	2502	-
DIS 0708	-	-	-
DIS 6500	-	-	-
DIF 01	-	DPI 08	-
DC 3100	-	-	-
DC 3110	-	2503	-
DC 3120	RDL220D	-	-
DIS 1120	-	-	-
DT2825	-	2003	-
DT 2120	-	4621	-
DT 2130	-	-	-
DT 2200	-	4622	-
DT 2300(Left)	-	4623	-
DT 2300(Right)	-	4623	-

Appendix page 2(2) Sign:




SP Technical Research Institute of Sweden

Postal address Phone / Fax Reg. number E-mail / Internet
 SP +46 10 516 50 00 556464-6874 info@sp.se
 Box 857 +46 33 13 55 02 www.sp.se
 SE-501 15 Borås
 SWEDEN

Swedish accredited certification bodies are appointed by SWEDAC, the Swedish Board for Accreditation and Conformity Assessment, under the terms of the Act. This certificate may not be reproduced other than in full, except with the prior written approval by SP.